

# SANDHYA ENTERPRISES

*AN ISO 9001:2015 Certified Company*

*# 5-24-1223/5/1, Ambedkar Nagar Gajularamaram, Gajularamaram, Near of UMCC Hoptial ,  
Qutuulapur Mandal R.R. Dist Hyderabad -500055 Telangana State India.*

*Contact No:9652998932, 95501921831,*

*Email: [sandhyaprises@gmail.com](mailto:sandhyaprises@gmail.com), [sandhyarubber@gmail.com](mailto:sandhyarubber@gmail.com),*

*Wessite:www.sandhyafex.com, www.sandhyaenterprises.co.in*

## **FIRE FIGHTING RUBBER SUCTION HOSE with Both end Male and Female Coupling AS PER IS:3549 and IS :902 Specification Make: "SANDHYAFEX"**



**Size:100mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**



**ize:100mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**



**ize:125mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**



**ize:125mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**



**ize:100mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**



**ize:100mm ID x 2.5Mtr(LG) IS:3549 (Type-1 & 2)Working Pressure: 10 kgf/ cm<sup>2</sup> Minimum Bursting Pressure: 30 kgf/ cm<sup>2</sup>**